

MSDS FOR HYDROGEN (COMPRESSED)

Rev 5(11/2005)

1. Identification of the Substance/ Preparation and of the Company

Product Name: **Hydrogen (Compressed)**
Chemical Formula: H_2
Company Identification: Energas Limited
Westmorland Street
Hull HU2 0HX

Emergency Telephone No: 01482 329333

2. Composition/ Information on Ingredients

Substance/ Preparation: Substance
Components/ Impurities: Contains no other impurities which will influence the classification of the product.

CAS Number: 01333-74-0
EEC Number: 001001009 (from EINECS)

3. Hazardous Properties

Compressed gas.
Extremely flammable (F+).

4. First Aid Measures

Inhalation:

In high concentrations may cause asphyxiation.
Symptoms may include loss of mobility/ consciousness.
Victim may not be aware of asphyxiation.
In low concentrations may cause narcotic effects.
Symptoms may include dizziness, headache, nausea and lack of co-ordination.
Remove victim to uncontaminated area wearing self-contained breathing apparatus.
Keep victim warm and rested. Call a doctor.
Apply artificial respiration if breathing has stopped.

Skin/ Eye Contact:

In case of cold burns, flush copiously with water, obtain medical attention.

Ingestion:

Ingestion is not considered a potential route of exposure.

5. Fire Fighting Measures

Suitable Extinguishing Media:

All known extinguishants can be used. Large fires should only be fought by the Fire Brigade.
Use dry powder or foam on small fires.

Specific Hazards:

Exposure to fire may cause containers to rupture/ explode.

Specific Methods:

If safe to do so, close cylinder valve.
Move container away or cool with water from a protected position.
Do not extinguish a leaking gas flame unless absolutely necessary, spontaneous re-ignition may occur. Extinguish any other fires in area.

Hazard Combustion Products:

None.

Special Protective Equipment for Fire Fighters:

In confined spaces use self-contained breathing apparatus.

6. Accidental Release Measures

Personal Precautions

Evacuate area.
Ensure adequate air ventilation.
Eliminate ignition sources.
Wear self-contained breathing apparatus when entering area unless atmosphere is proved to be safe.

Environmental Precautions

Try to stop release. Lighter than air.

Clean Up Methods

Ventilate area.

7. Handling and Storage

Handling:

Refer to Energas Storage and Handling instructions.
Ensure equipment is earthed.
Use only properly specified equipment which is suitable for this product, its supply pressure and temperature.
Do not allow backfeed into the container.
Contact Energas Limited if in doubt.

MSDS FOR HYDROGEN (COMPRESSED)

Rev 5(11/2005)

Storage:

Store out of doors or in a well ventilated store room.
Segregate from oxidant gases or other flammable materials in store.
Keep away from ignition sources including static discharges.
Keep container below 50°C in a well ventilated place.
DO NOT SUBJECT CYLINDER TO SHOCK.

8. Exposure Controls/ Personal Protection

Personal Protection:

Ensure adequate ventilation.
Do not smoke while handling product.
Wear eye protection.

9. Physical and Chemical Properties

Appearance/ Colour: Colourless gas.
Odour: Odourless

Molecular Weight: 4
Melting Point: -259°C
Boiling Point: -253°C
Critical Temperature: -240°C
Relative Density (Liquid): 0.07 (water = 1)
Relative Density (Gas): 0.07 (air = 1)
Vapour Pressure @ 20°C: Not applicable
Solubility (water): 1.6 mg/l
Auto Ignition Temperature: 571°C
Flammability Range: 4 – 75 vol. % in air

10. Stability and Reactivity

Can form explosive mixture with air.
May react violently with oxidants.

11. Toxicological Information

No known toxicological effects from this product.

12. Ecological Information

No known ecological effects from this product.

13. Disposal Considerations

Do not discharge into areas where there is a risk of forming an explosive mixture with air, or where its accumulation could be dangerous.
Waste gas should be flared through a suitable burner with flash back arrestor.
Contact Energas Limited if guidance is required.

14. Transport Information

UN No. : 1049
Class/ Division : 2.1
ADR/RID item : 1F
Emergency Action Code : 2SE
Hazard Identification No. : 23
CEFIC Tremcard No. : 20/20g32
Labelling ADR : Label 2.1: Flammable gas.

Avoid transport on vehicles where the load space is not separated from the driver's compartment.
Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the event of an accident or emergency.
Ensure all cylinder valves are closed and not leaking and the load is firmly secured and complies with the applicable regulations.

15. Regulatory Information

EC Classification: F+; R12

- Symbols - road transport symbols are used and selected to the most stringent product classification.

EC or ADR - Label 2.1: Flammable gas.

- Risk Phrases

R12 Extremely flammable.

- Safety Phrases

S9 Keep container in a well ventilated place.
S16/33 Keep away from ignition sources including static discharges.

16. Other Information

Valve Connection: BS 341 No. 4

Ensure all users of this product understand the flammability hazard and hazards of asphyxiation.
Before using this product in any new process or experiment, a thorough material compatibility and safety study should be carried out.

Details given in this document are believed correct at the time of going to press.

Whilst proper care has been taken in the preparation of this document, no liability for injury or damage resulting from its use can be accepted.



**MSDS FOR
HYDROGEN (COMPRESSED)**

Rev 5(11/2005)

Refer to Energas Limited General Safety and Handling Data Sheet for further details.

MSDS FOR HYDROGEN (COMPRESSED)

Rev 5(11/2005)

**CYLINDER IDENTIFICATION TO BS EN 1089-3
SHOULDER COLOUR: FLAME RED (RAL 3000) (Green Neck Ring)**

ENERGAS GENERAL SAFETY AND HANDLING DATA

1. GENERAL

Only trained persons should handle compressed gases.
Observe all regulations and local requirements regarding the storage of containers.
Do not remove or deface labels provided by the supplier for the identification of the container contents.
Ascertain the identity of the gas before using it.
Know and understand the properties and hazards associated with each gas before using it.
When doubt exists as to the correct handling procedure for a particular gas contact the supplier.

2 HANDLING AND USE

Wear stout gloves.
Never lift a container by the cap or guard unless the supplier states it is designed for that purpose.
Use a trolley or other suitable device or technique for transporting heavy containers, even for a short distance.
Where necessary wear suitable eye and face protection. The choice between safety glasses, chemical goggles, or full-face shield will depend on the pressure and nature of the gas being used.

Where necessary for toxic gases see that self-contained positive pressure breathing apparatus or full face air line respirator is available in the vicinity of the working area.
Employ suitable pressure regulating devices on all containers when the gas is being emitted to systems with a lower pressure rating than that of the container.
Ascertain that all electrical systems in the area are suitable for service with each gas.

Never use direct flame or electrical heating devices to raise the pressure of a container. Containers should not be subjected to temperatures above 45°C.
Never re-compress a gas mixture without consulting the supplier. Never attempt to transfer gases from one container to another.
Do not use containers as rollers or supports, or for any other purpose than to contain the gas as supplied.
Never permit oil, grease or other readily combustible substances to come into contact with valves of containers containing oxygen or other oxidants.

Keep container valve outlets clean and free from contaminants, particularly oil and water.
Do not subject containers to abnormal mechanical shocks which may cause damage to their valves or safety devices.

Never attempt to repair or modify container valves or safety relief devices. Damaged valves should be reported immediately to the supplier.
Close the container valve whenever gas is not required even if the container is still connected to the equipment.

3 STORAGE

Containers should be stored in a well-ventilated area. Some gases will require a purpose built area.
Store containers in a location free from fire risk and away from sources of heat and ignition. Designation as a no smoking area may be desirable.

Gas containers should be segregated in the storage area according to the various categories.

The storage area should be kept clear and access should be restricted to authorised persons only, the area should be clearly marked as a storage area and appropriate hazard warning signs displayed (Flammable Toxic etc.).
The amount of flammable or toxic gases should be kept to a minimum.
Flammable gases should be stored away from other combustible materials.

Containers held in storage should be periodically checked for general condition and leakage.
Containers in storage should be properly secured to prevent toppling or rolling.
Vertical storage is recommended where the container is designed for this.
Container valves should be tightly closed and where appropriate, valve outlets should be capped or plugged. Protect containers stored in the open against rusting and extremes of weather.
Containers should not be stored in conditions likely to encourage corrosion.
Store full and empty containers separately and arrange full containers so that the oldest stock is used first.

PRODUCTION SITE ADDRESSES

Engineering and Welding Limited
Westmorland Street
Hull
HU2 0HX

Energas Limited
Haslams Lane
Alfreton Road
Derby, DE22 1EB

Energas Limited
Brownroyd Street
Off Thornton Road, Bradford
West Yorkshire, BD8 9AF

Tel: 01482 329333
Fax: 01482 212335

Tel: 01332 364121
Fax: 01332 291590

Tel: 01274 549090
Fax: 01274 548181

FOR FURTHER INFORMATION CONTACT YOUR NEAREST DISTRIBUTION CENTRE